



Purchasing Division

## ADDENDUM NO. 1

**DATE:** September 3, 2019  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** 2019 Fire Training Facility- Building Foundation IFB-4690-19-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. Detail D on drawing sheet 6 is showing class 6 on top of the class 1 backfill at a width of 2'. No pay item is listed for the class 6, thickness is not shown and width does not match the strip footings. Please advise on how this item should be bid.

A. The ABC Class 6 backfill surrounding the 24-inch deep footings shall be 20 inches deep. The ABC Class 6 backfill surrounding the 18-inch deep footing shall be 12 inches deep. Total quantity of ABC Class 6 is approximately 910 CY. The Contractor shall include the cost of this backfill in the cost of the concrete footings (Item 601 Concrete Class D).

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink, appearing to read "Duane Hoff Jr.", written over a set of horizontal lines.

Duane Hoff Jr., Senior Buyer  
City of Grand Junction, Colorado