



Purchasing Division

ADDENDUM NO. 2

DATE: September 26, 2019
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: Boiler Replacements for Lincoln Park Club House and Tiara Rado Club House
IFB-4696-19-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. At Tiara Rado currently there is not enough combustion air for the BTU load of the existing boiler and water heater. Would the City like the contractors to price adding louvers in the doors to increase the combustion air for the room to meet the combustion air requirements?

A. Yes.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink, appearing to read "Duane Hoff Jr.", written over a white background.

Duane Hoff Jr., Senior Buyer
City of Grand Junction, Colorado