



Purchasing Division

## **ADDENDUM NO. 5**

**DATE:** December 19, 2019  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** Suplizio Stadium Structural Repairs IFB-4729-20-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. Regarding question & response #11 from Addendum #2, please clarify if the seat pans that are to be marked for replacement are to be included in base bid or add alternate.

A. The contractor shall provide a price on the Add Alternative to replace the entire seating pans in Sections P through S.

2. Q. If seat pans are to be replaced (other than beneath treads and landings), please indicate if pan will need to be replaced in its entirety (from beam to beam) or if it can be repaired mid-span. If pans are to be repaired mid-span, please confirm that a full penetration weld is required.

A. The only seat pans to be replaced are those in the Add Alternative to replace Sections P through S. Those seat pans shall span from beam to beam.

3. Q. Please see attached product data for SW Hi-Solids Metal Primer and SW Acrolon 100 topcoat. Will these products be acceptable?

A. We do not accept these products. We are concerned about the durability of these coatings.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink, appearing to read "Duane Hoff Jr.", written over a white background.

Duane Hoff Jr., Senior Buyer  
City of Grand Junction, Colorado