

**Purchasing Division** 

## ADDENDUM NO. 6

DATE: December 20, 2019

- FROM: City of Grand Junction Purchasing Division
- TO: All Offerors

## RE: Suplizio Stadium Structural Repairs IFB-4729-20-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. I have some subcontractors who would like to see the existing conditions. Can we visit the site again?

A. No. We already allowed for an additional site visit earlier in the process.

2. Q. What steel testing needs to be performed? Do the welds connecting the treads to the risers need to be tested or just the structural components?

A. All structural steel installed on the project shall be tested and/or inspected in accordance with the Mesa County adopted International Building Code - Section on Special Inspections and Tests. The stairs may not need to be inspected, at the discretion of the Mesa County Building Department.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

Duane Hoff Jr., Senior Buyer City of Grand Junction, Colorado