



Purchasing Division

## ADDENDUM NO. 2

**DATE:** April 14, 2020  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** 2020 Horizon Place Street Reconstruction IFB-4784-20-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. #3 8" gate valve- Plans only show 1, bid has 3. 6" gate valve for the hydrant not on the bid. Assuming this is an Ute water line and they are tapping the 8" line?

A. The plans are correct. Please see the updated bid schedule. However, this will be a City water line and the Contractor shall be responsible for tapping the 8" main. Contractor shall utilize the attached updated Addendum 2 Price Bid Schedule when submitting their bid responses.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink, appearing to read "Duane Hoff Jr.", written over a white background.

Duane Hoff Jr., Senior Buyer  
City of Grand Junction, Colorado

## Bid Schedule: Horizon Place Addendum #2

**Contractor:** \_\_\_\_\_

Item No.	CDOT, City Ref.	Description	Quantity	Units	Unit Price	Total Price
1	108.2	Water Main (6") (C-900, DR-18)(Includes cost of restrained connection to existing pipe)	19.	LF	\$ _____	\$ _____
2	108.2	Water Main (8") (C-900, DR-18) (Includes cost of restrained connection to existing pipe)	26.	LF	\$ _____	\$ _____
3	108.3	6" Gate Valve(Restrained Fitting)(Epoxy Coated)	1.	EA	\$ _____	\$ _____
4	108.3	8" Gate Valve(Restrained Fitting)(Epoxy Coated)	1.	EA	\$ _____	\$ _____
5	108.3	Tee (8" x 6") MJ Swivel Tee (Epoxy Coated)	1.	EA	\$ _____	\$ _____
6	108.3	Elbow (8" x 45 deg)(Epoxy Coated)	2.	EA	\$ _____	\$ _____
7	108.3	Cap (8")	1.	EA	\$ _____	\$ _____
8	108.3	Fire Hydrant Assembly	1.	EA	\$ _____	\$ _____
9	201	Clear and Grub Trees/Vegetation(Approx. 1,308 SY)		Lump Sum	---	\$ _____
10	202	Concrete Curb, Gutter, Sidewalk, V-Pan & Dumpster Pad Removal & Disposal	180.	SY	\$ _____	\$ _____
11	202	Asphalt Removal and Disposal	1,664.	SY	\$ _____	\$ _____
12	202	Storm Sewer Manhole Removal and Disposal	1.	EA	\$ _____	\$ _____
13	202	Dumpster Enclosure Removal and Disposal	1.	EA	\$ _____	\$ _____
14	202	Tree Removal and Disposal	2.	EA	\$ _____	\$ _____
15	202	Chain Link Fence Removal and Disposal	30.	LF	\$ _____	\$ _____
16	202	Fire Hydrant Removal and Disposal	1.	EA	\$ _____	\$ _____
17	203	Earthen Ditch	165.	LF	\$ _____	\$ _____
18	203	Excavation	1.	LS	\$ _____	\$ _____
19	208	Rip Rap Outlet Protection Structures	30.	LF	\$ _____	\$ _____
20	208	Erosion Control (Complete In Place) (To Include Earthwork)		Lump Sum	---	\$ _____
21	208	Vehicle Tracking Pad	1.	EA	\$ _____	\$ _____
22	208	Temporary Berms		Lump Sum	---	\$ _____
23	208	Concrete Wash Out Pit & Maintenance		Lump Sum	---	\$ _____

## Bid Schedule: Horizon Place Addendum #2

**Contractor:** \_\_\_\_\_

Item No.	CDOT, City Ref.	Description	Quantity	Units	Unit Price	Total Price
24	208	Stormwater Management		Lump Sum	---	\$ _____
25	210	Relocate Street Signs	6.	EA	\$ _____	\$ _____
26	210	Landscaping to Match Existing		Lump Sum	---	\$ _____
27	304	Aggregate Base Course (Class 6) (12" Thickness)	1,350.	Tons	\$ _____	\$ _____
28	306	Subgrade Reconditioning (12" Deep)	2,814.	SY	\$ _____	\$ _____
29	401	Hot Mix Asphalt (4" thick) (Grading SX-75, Binder Grade 64-22)	625.	Tons	\$ _____	\$ _____
30	607	Trash Enclosure Fence	48.	LF	\$ _____	\$ _____
31	607	Trash Enclosure Gate	18.	LF	\$ _____	\$ _____
32	608	Concrete Curb Ramp - 20' Radius ADA Alternate Ramp with Cast Iron Wet Set ADA Detectible Mat	1.	EA	\$ _____	\$ _____
33	608	Concrete Curb Ramp - 20' Radius ADA Curb Return with Cast Iron Wet Set ADA Detectible Mat	1.	EA	\$ _____	\$ _____
34	608	Concrete Dumpster Pad (8" Thick)	42.	SY	\$ _____	\$ _____
35	608	Concrete Driveway (8" Thick)	110.	SY	\$ _____	\$ _____
36	608	Monolithic Curb, Gutter, Sidewalk (7' Wide)	324.	LF	\$ _____	\$ _____
37	608	1'6" Concrete Spill Curb and Gutter (To Include Subgrade Excavation, Reconditioning, & 6" Class 6 ABC)	521.	LF	\$ _____	\$ _____
38	608	2' Concrete Curb and Gutter (To Include Subgrade Excavation, Reconditioning, & 6" Class 6 ABC)	73.	LF	\$ _____	\$ _____
39	614	End of Roadway Signs	3.	EA	\$ _____	\$ _____
40	620	Sanitary Facility		Lump Sum	---	\$ _____
41	625	Construction Surveying		Lump Sum	---	\$ _____
42	626	Mobilization		Lump Sum	---	\$ _____
43	630	Traffic Control (Complete In Place)		Lump Sum	---	\$ _____
44	630	Traffic Control Plan		Lump Sum	---	\$ _____
MCR		Minor Contract Revisions	---	---	---	\$ <u>15,000.00</u>

**Bid Amount:** \$ \_\_\_\_\_

**Bid Amount:** \_\_\_\_\_

**dollars**