



Purchasing Division

ADDENDUM NO. 1

DATE: April 22, 2020
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: Pipe Purchase for Kannah Creek Flowline Replacement IFB-4791-20-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. Are there any specific brand of pipe that is excluded?
A. No, as long as the pipe is AWWA approved and DR 25 rating.
2. Q. Does tracer wire need to be added to the bid?
A. No.
3. Q. "Mega Lugs" are called out in the materials, are other brands of joint restraints acceptable?
A. Other brands are acceptable as long as they meet the Mega Lug specifications.
4. Q. What is the insurance requirement?
A. See Section 2.6 "Insurance Requirements" of the solicitation document.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink, appearing to read "Duane Hoff Jr.", written over a white background.

Duane Hoff Jr., Senior Buyer
City of Grand Junction, Colorado