



Purchasing Division

ADDENDUM NO. 1

DATE: April 27, 2020
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: 2020 Victor Drive Sewer Improvement District Project IFB-4789-20-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. Will structural flow-fill material be required for backfill around the 90-degree sweep elbow at station 2+54?

A. No, Type A pipe bedding can be used for supporting the 90-degree elbow.

2. Q. What are the trench compaction requirements for the segment of trench that's on the shoulder of Victor Drive?

A. Compaction requirements for this Project shall follow Table 101 within the Standard Specifications for the Construction of Underground Utilities. The City will require trench backfill compaction, whether native or imported soil, that is within City right-of-way to be compacted to a 95% minimum per AASHTO T 99. The City will use RockSol Consulting Group for quality assurance testing on compaction of trench backfill material.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink, appearing to read "Duane Hoff Jr.", written over a light blue rectangular background.

Duane Hoff Jr., Senior Buyer
City of Grand Junction, Colorado