



Purchasing Division

ADDENDUM NO. 1

DATE: April 30, 2020
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: Lunch Loop Trailhead Improvements IFB-4797-20-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. There is a small bit of 18" storm drain pipe on the project and I wanted to see if you'll allow an alternate to the RCP called out. I would propose HP Storm which is a CDOT approved corrugated polypropylene pipe. It's 2x stiffer than HDPE and has an improved joint.

A. We will allow ADS HP Storm pipe as an alternate to the RCP proposed on this project.

2. Q. Wanted to check with you and see if we can quote Nyloplast inlets with Flexstorm inlet protection bags. The benefit to Nyloplast Structures is the on site flexibility, water tight joints to mitigate infiltration of soils into the storm drain, and an H-20 rating with concrete collar. Nyloplast offer the 2x3 curb inlet called out in the project details. These Nyloplast structures are currently also being evaluated by CDOT and being approved on a case by case basis.

A. We will allow Nyloplast inlets as an alternate to the precast concrete inlet and steel inlet grate.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink, appearing to read "Duane Hoff Jr.", written over a white background.

Duane Hoff Jr., Senior Buyer
City of Grand Junction, Colorado