



Purchasing Division

ADDENDUM NO. 3

DATE: August 27, 2020
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: 2020 Sewer Line Replacement Project
IFB-4821-20-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. After reaching out to subs for the epoxy coating for the MH's on your project, we have received the following request to add RestoKrete as a Resurfacers and SewerGard as the protective lining. Let us know if this alternate is acceptable?
 - A. *The City of Grand Junction approves the use of Sauereisen RestoKrete Epoxy Modified Cement No. 208 as a resurfacers and the SewerGard 210 XHB as the protective lining for the 2020 Sewer Line Replacement Project.*

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink, appearing to read "Duane Hoff Jr.", written over a white background.

Duane Hoff Jr., Senior Buyer
City of Grand Junction, Colorado