



Purchasing Division

ADDENDUM NO. 1

DATE: March 4, 2021
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: Pipe Purchase – Anderson Ranch Section of Kannah Creek Flowline Replacement
IFB-4884-21-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. Is the butterfly valve on this bid std 150# pressure class? Or is it 250# pressure class?
 - A. 150# pressure class.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink, appearing to read "Duane Hoff Jr.", written over a white background.

Duane Hoff Jr., Senior Buyer
City of Grand Junction, Colorado