



Purchasing Division

ADDENDUM NO. 1

DATE: April 28, 2021
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: Persigo Wastewater Treatment Plant Large Repairs IFB-4910-21-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. I couldn't make a determination if temporary mobile solids dewatering was required or sludge removal was part of the scope. Could you please respond if these type of services are required for your project?

A. Persigo Wastewater Treatment Plant will clean each structure to the best of its ability after shutdown of the structure and prior to handing it over to the awarded General Contractor. Any additional sludge removal, solids dewatering or disposal services will be the responsibility of the awarded GC.

2. See the updated [Price Bid Schedule](#) (Link). Contactors shall utilize the updated Addendum 1 Price Bid Schedule when submitting their bid responses.

3. Q. Will there be a need for any sludge removal, dewatering, or disposal services?

A. Persigo Wastewater Treatment Plant will clean each structure to the best of its ability after shutdown of the structure and prior to handing it over to the awarded General Contractor. Any additional sludge removal, solids dewatering or disposal services will be the responsibility of the awarded GC.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink, appearing to read "Duane Hoff Jr.", written over a white background.

Duane Hoff Jr., Senior Buyer
City of Grand Junction, Colorado