



Purchasing Division

ADDENDUM NO. 1

DATE: August 16, 2021
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: Mobile Office Trailer RFP-4935-21-SH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

Question 1: In regards to the Fire Alarm, do you need a smoke detector or full sprinkler system?

Answer: A smoke detector is sufficient.

Question 2: None of our restroom units are fully contained. Typically a 250 gallon sewage holding tank is hooked up on site and sits below the unit. Will this work?

Answer: Yes.

Question 3: Would you accept a delivery date in Late October/early November for the new mobile buildings?

Answer: Yes. Please include the delivery in your proposal.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Susan J. Hyatt". The signature is written in a cursive style and is positioned above the typed name.

Susan Hyatt, Senior Buyer
City of Grand Junction, Colorado