



Purchasing Division

## **ADDENDUM NO. 4**

**DATE:** December 30, 2021  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** Professional Engineering Services Consultant for Wastewater Treatment Plant Expansion Projects RFP-4972-22-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. The RFP and Master Plan scope of work for Disinfection Operational Improvements Project only includes purchasing additional UV modules to serve as spares to the existing UV modules. The scope and budget for this Project in the Master Plan does not include adding a second UV channel. During the site walk at the Site Visit meeting, it was stated by the City that the project would include adding a second UV channel. Should the Engineer include the design of the second UV channel in their scope and fee?
  - A. Yes, please include the design of the second UV channel in your scope and fee.
2. Q. The RFP doesn't mention installing a building or canopy over the UV system, but this was discussed as a project need during the site walk. Should the Engineer include in our design fee a new building, and if so what type of building should we assume (example: canopy, PEMB, etc.).
  - A. Yes, please include in the scope and design to install an enclosure around the UV systems. We are interested in a practical and low cost solution such as a pre-engineered metal building or canopy. We'd like the selected firm to recommend what type of enclosure is most applicable.
3. Q. Addendum No. 1 – Response to Question 12 doesn't include a cost for the UV improvements. Please Include the project's UV budget.
  - A. As noted above, the masterplan didn't specify the design of the second UV channel or to add an enclosure around UV. For this reason we don't have an estimated cost for the UV improvements.

4. Q. The RFP and Master Plan scope of work for Dewatering Building and Solids Storage Project including the budget in Appendix H does not include a sludge blending tank. During the site walk at the Site Visit meeting, it was stated by the City that the project would include a new sludge blending tank. Should the Engineer include the design of the sludge blending tank in their scope and Fee?

A. Yes, please include the design of the sludge blending tank in your scope and fee.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink, appearing to read "Duane Hoff Jr.", written in a cursive style.

Duane Hoff Jr., Senior Buyer  
City of Grand Junction, Colorado