



Purchasing Division

## ADDENDUM NO. 1

**DATE:** January 3, 2022  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** 2022 28.25 and Hawthorne Avenue Intersection Improvements IFB-4988-22-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. Can corrugated HDPE pipe be used in place of the RCP?  
A. HDPE pipe will not be allowed to be used in place of RCP.
2. Q. I do not see an item for sidewalk (4" thick). My take off shows approx 460 SY.  
A. See Item 26 of the Price Bid Schedule attached to the original solicitation document.
3. Q. Can you clarify if aggregate base course quantities include the base course under the detached sidewalks?  
A. The aggregate base course quantity has been changed on the revised bid schedule, and now reflects total tonnage anticipated for the roadway, attached sidewalks, and detached sidewalks.
4. Q. Has irrigation on west side been located or do you anticipate needing to the Contractor to field verify location? If so, could pay item for potholing hours be added to bid schedule?  
A. The irrigation line was not located during potholing. Potholes were conducted on the locate, and to each side 8 feet deep without locating the line. The revised bid schedule reflects an additional pay item.
5. Q. Does the City anticipate needing to haul excavated materials off site?  
A. Material can be wasted on site at the direction of the engineer.
6. Q. Does the City want to stockpile the existing top 6" of soil for use in landscape areas?  
A. The top 6" of soil will be maintained separately from the rest of the excavated material for use as topsoil.
7. Q. Section 3.3.39 includes a pay factor for Hot Mix Asphalt that includes a disincentive. Can pay factor be revised to include an incentive payment or just accept asphalt based on densities with no pay factor?

A. This project has less than three sub-lots, therefore payment shall be 100% provided that the materials tested meet the requirements of Section 401.05.2.

8. Q. Is a 48" diameter manhole desired?

A. Yes, if available.

9. Q. Can an eccentric cone section with the bottom notched out substitute the flat top lid manhole?

A. Possibly, can be considered with a submittal.

10. The following changes have been made to the Bid Schedule:

Removed

- Item 2 – Removal Tree
- Item 4 – Removal of Bollard
- Item 7 – Removal of Pavement Marking
- Item 17 – Relocate Water Valve

Changed

- Item 9 – Sawing Asphalt Mat (*Full Depth*)
- Item 23 – ABC (CI 6) – quantity adjusted to 2,300 (TON)
- Item 29 – 18 Inch Reinforced Concrete End Section – quantity adjusted to 3 (EA)
- Item 30 – *Storm Drain Manhole (48" I.D.) with Flat Top Lid*
- Item 31 – *Reset 16' Ranch Gate with U-Channel Posts*

Added

- Item 42 – Sign Panel - Stop Sign (R1-1)(30"x30")
- Item 43 – Sign Panel - Street Name Signs (D3-1)(Varies x 12")(Typical Round Steel Pole with Slip Base Assembly)
- Item 44 – Subgrade Stabilization per plan detail
- Item 45 – 4 Inch diameter Schedule 40 PVC Irrigation Conduit (Purple)
- Item 46 – Potholing for Irrigation Line
- Item 47 – Thermoplastic Pavement Markings (White Left Turn)
- Item 48 – Thermoplastic Pavement Markings (Bike Lane)

Contractors shall utilize the attached updated Addendum 1 Price Bid Schedule when submitting their bid responses.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,



Duane Hoff Jr. Senior Buyer  
City of Grand Junction, Colorado

## Addendum 1 Price Bid Schedule

Item No.	CDOT, City Ref. Description	Quantity	Units	Unit Price	Total Price
1	CLEAR AND GRUB	1.	LS	\$ _____	\$ _____
3	REMOVAL OF PIPE	69.	LF	\$ _____	\$ _____
5	REMOVAL ASPHALT MAT (FULL DEPTH)	11.56	SY	\$ _____	\$ _____
6	REMOVAL ASPHALT MAT (PLANING) 2" MILL	29.22	SY	\$ _____	\$ _____
8	REMOVAL GROUND SIGN (RETURN TO TRAFFIC DEPT AT THE CITY SHOPS)	10.	EA	\$ _____	\$ _____
9	SAWING ASPHALT MAT (FULL DEPTH)	66.	LF	\$ _____	\$ _____
10	REMOVAL OF FENCE	116.	LF	\$ _____	\$ _____
11	UNCLASSIFIED EXCAVATION	2,417.	CY	\$ _____	\$ _____
12	EROSION CONTROL LOG TYPE 1 (9 IN)	1,150.	LF	\$ _____	\$ _____
13	AGGREGATE BAG	30.	LF	\$ _____	\$ _____
14	CONCRETE WASHOUT	1.	EA	\$ _____	\$ _____
15	STORM DRAIN INLET PROTECTION (TYPE II)	6.	EA	\$ _____	\$ _____
16	VEHICLE TRACKING PAD	2.	EA	\$ _____	\$ _____
18	Adjust Manhole	1.	EA	\$ _____	\$ _____
19	SEEDING (NATIVE)	11,300.	SF	\$ _____	\$ _____
20	ROCK MULCH (WEED FREE)	4,020.	SF	\$ _____	\$ _____
21	LANDSCAPE WEED BARRIER FABRIC	446.67	SY	\$ _____	\$ _____
22	ADJUST VALVE BOX	2.	EA	\$ _____	\$ _____
23	ABC (CL 6)	2,300.	TON	\$ _____	\$ _____
24	RECONDITIONING (12" DEPTH)	3,459.22	SY	\$ _____	\$ _____
25	Hot Mix Asphalt (Grading SX) (75) (PG 64-22)	845.	TON	\$ _____	\$ _____
26	Concrete Sidewalk (4 Inch)	462.	SY	\$ _____	\$ _____
27	RIPRAP (9 INCH)	40.89	CY	\$ _____	\$ _____
28	18 Inch Reinforced Concrete Pipe (Complete In Place)	93.	LF	\$ _____	\$ _____
29	18 Inch Reinforced Concrete End Section	3.	EA	\$ _____	\$ _____
30	Storm Drain Manhole (48" I.D.) with Flat Top Lid	1.	EA	\$ _____	\$ _____
31	Reset 16' Ranch Gates with U-Channel Posts	2.	EA	\$ _____	\$ _____
32	Concrete Intersection corner	147.	SY	\$ _____	\$ _____
33	Detectable Warnings	16.	SF	\$ _____	\$ _____
34	City Curb with Spill Gutter	576.	LF	\$ _____	\$ _____
35	City Standard Curb and Gutter	647.	LF	\$ _____	\$ _____
36	Monolithic Drive Over Curb, Gutter and Sidewalk (6'-6" wide)	283.	LF	\$ _____	\$ _____
37	Concrete Drainage Pan (6'-0" width)	38.	LF	\$ _____	\$ _____
38	Median Cover Material (Concrete) 6" Thickness	25.	SY	\$ _____	\$ _____
39	Construction Surveying	1.	LS	\$ _____	\$ _____
40	Mobilization	1.	LS	\$ _____	\$ _____
41	Traffic Control (Complete In Place)	1.	LS	\$ _____	\$ _____
42	Sign Panel - Stop Sign (R1-1)(30"x30")	1.	EA	\$ _____	\$ _____
43	Sign Panel - Street Name Signs (D3-1)(Varies x 12")(Typical Round Steel Pole with Slip Base Assembly)	1.	EA	\$ _____	\$ _____
44	Subgrade Stabilization per plan detail	350.	SY	\$ _____	\$ _____

## Addendum 1 Price Bid Schedule

Item No.	CDOT, City Ref. Description	Quantity	Units	Unit Price	Total Price
45	4 Inch diameter Schedule 40 PVC Irrigation Conduit (Purple) with end caps and 4"x4" utility markers	350.	LF	\$ _____	\$ _____
46	Potholing for Irrigation Line	4.	HOUR	\$ _____	\$ _____
47	Thermoplastic Pavement Markings (White Left Turn)	2.	EA	\$ _____	\$ _____
48	Thermoplastic Pavement Markings (Bike Lane)	2.	EA	\$ _____	\$ _____
MCR	Minor Contract Revisions	---	---	---	\$ 15,000.00

**Bid Amount:** \$ \_\_\_\_\_

**Bid Amount:** \_\_\_\_\_

**dollars**