



Purchasing Division

ADDENDUM NO. 1

DATE: April 12, 2022
FROM: City of Grand Junction Purchasing Division
TO: All Interested Parties
RE: Re-Roof Orchard Mesa Persigo Office IFB-5027-22-SH

Bidders responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following:

Question 1. What is the estimated cost?

Answer: Estimated costs will not be shared.

NOTICE: The original bid document did not provide complete information for the Gutters in Section 3.3 Bid Alternate. Use this information when providing the Bid Price on Item 2.

Scope of Work shall now read:

BID ALTERNATE:

18. Install a six-inch (6") K style gutter with 3 inch x 4 inch down spouts, no single run gutters.
19. Gutters on North side are 65 feet (65') in length with no split and two (2) downspouts.
20. Gutters on Northwest side are 21 feet (21') in length with no split and one (1) downspout.
21. Gutters on South side are 90 feet (90') in length, split in the middle to run East and West with a downspout on each end.
22. Overall estimated length is 176 feet.
23. There will be five (5) total downspouts.

The original solicitation for the project referenced above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Susan J. Hyatt".

Susan Hyatt, Senior Buyer
City of Grand Junction, Colorado