



Purchasing Division

ADDENDUM NO. 1

DATE: April 18, 2022
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: Tiara Rado Force-main Replacement Project IFB-5066-22-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. On the referenced project, curious what type of installation method is being used (open cut, directional drill, pipe bursting, etc.)?
 - A. *On this Project, the installation of the new 12" Fusible HDPE pipe shall use the open cut (trenching) method for pipeline installation.*

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink, appearing to read "Duane Hoff Jr.", written over a white background.

Duane Hoff Jr., Senior Buyer
City of Grand Junction, Colorado