



Purchasing Division

ADDENDUM NO. 2

DATE: September 26, 2022
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: IFB-5107-22-DD Persigo Wastewater Treatment Plant Floating Mechanical Aerators/Mixers

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. **Question:** Warranty concerns in # 4 below applies equally to DBS and Aeration Industries and should be clarified.

The warranty should start **as soon as all 6 aerators are operable** – not when all 6 are put into operation which could be weeks, months or years.

4. Section 1.07 A. states warranty starts when owner accepts **all units** in operation. Section 3.04B. 1. Only requires 4 mixers in the northern basin be put into operation. The remainder are to be “bumped” to confirm that they work (I assume in the proper direction). If any aerator is not put into operation the warranty on all aerators is extended. We will require all units to be put into operation to demonstrate proper operation during one of the scheduled site visits.

Answer: The warranty period will begin upon placing all 6 mixer/aerators in operation. This includes the 4 mixer/aerators in the northern most basin as well as 'bumping' the additional 2 aerator/mixers. This should occur during one of the scheduled site visits.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Dolly Daniels". The signature is written in a cursive, flowing style.

Dolly Daniels, Senior Buyer
City of Grand Junction, Colorado