



Purchasing Division

## ADDENDUM NO. 5

**DATE:** December 9, 2022  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** IFB-5134-22-DD 2022 24 Road Multi-modal Path Construction  
CDOT Project No. MTF M555-035 (24077)

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

- Question:** I do not see a note for a centerline joint on the proposed path. ACI allows for 12' joint spacing with the proposed (6") thickness. Does the City want a centerline joint on the proposed path?

**Answer:** Yes, please include a centerline joint on the bike path and every 8' feet transverse.
- Question:** Item #27- Will ADS HP corrugated pipe (CDOT approved type) be accepted as an alternate to the RCP? Also, plans just show "pipe end", is that to mean the ends will remain open? Or is there something like a grate or flare end section to be at the end of the pipes?

**Answer:** ADS HP Pipe will not be accepted as an alternative. RCP material is required. The ends will remain open. Grates or flare ends are not required.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Dolly Daniels". The signature is written in a cursive, flowing style.

Dolly Daniels, Senior Buyer  
City of Grand Junction, Colorado