



Purchasing Division

## ADDENDUM NO. 6

**DATE:** December 9, 2022  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** IFB-5134-22-DD 2022 24 Road Multi-modal Path Construction  
CDOT Project No. MTF M555-035 (24077)

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

- Question:** The project specials introduce a DF concrete to the CDOT table of classes of concrete. However, I do not see it called out, or directed to be used in the specs or the plans. The detail for the bike path calls out a CDOT class B, and the bridge calls out for a CDOT class D. Is the class DF to be used for any purpose on this project.

**Answer:** There is no Class DF concrete on this project. CDOT requires this Standard Special Provision for Class DF concrete on all projects with concrete. So we included it. In the end, there is no Class DF concrete on this project.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Dolly Daniels". The signature is written in a cursive, flowing style.

Dolly Daniels, Senior Buyer  
City of Grand Junction, Colorado