



Purchasing Division

## **ADDENDUM NO. 6**

**DATE:** February 24, 2023  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** IFB-5176-23-DD Purdy Mesa Flowline Pressure Control Tank

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

- 1. Question:** It was stated in the pre-bid that a round tank would be required. What are the tolerances for roundness? Will a slip form be required or can we use Symons forms? If Symons forms are permitted the tank would essentially be round but have flat spots created by the forms themselves.

**Answer:** Symons forms are acceptable. Available volume to meet operation requirements is the primary requirement for the tank. A generally cylindrical shape that meets the structural design criteria for minimum thicknesses and rebar coverage is acceptable.
- 2. Question:** Clarify who is responsible for the survey.

**Answer:** The Contractor is responsible for all construction staking and as-built survey.
- 3. Question:** Will the Contractor be responsible for soil and concrete testing?

**Answer:** The Contractor is responsible for all quality control testing. The City will provide quality assurance testing. Refer to the Project Manual and City of Grand Junction Standard Contract Document for testing schedule and requirements.
- 4. Question:** Can Val-Matic be named for the AWWA BFVs (section 02616,2.9 A/B) and Check Valves (CVs) although I couldn't find an actual spec section on the checks. They were just reference in the schedule. I see you have Val-Matic as accepted manufacturer for the plug valves.

**Answer:** Yes, Val-Matic BFVs are acceptable. Val-Matic is also acceptable for check valves.
- 5. Question:** Could Proco be approved for the Duckbill Check Valves (ECVs)?

**Answer:** Yes, Proco is an acceptable brand for duckbill check valves.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Dolly Daniels". The signature is written in a cursive style with a blue ink color.

Dolly Daniels, Senior Buyer  
City of Grand Junction, Colorado