



Purchasing Division

## **ADDENDUM NO. 1**

**DATE:** May 15, 2023  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** Roof Replacements IFB-5246-23-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

- 1. City Hall and City Offices**  
The roof should be fully adhered for both buildings
- 2. City Hall**  
Replace all roof jacks and boots
- 3. City Offices**  
All electrical and plumbing will be handled by the City.  
All piping and conduit support blocks need to be rubber.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Dolly Daniels".

Dolly Daniels, Senior Buyer  
City of Grand Junction, Colorado