



Purchasing Division

ADDENDUM NO. 2

DATE: August 2, 2023
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: Crawford Rockaway Alley Improvements IFB-5276-23-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

- 1. Question:** How is the conflict between the proposed alley pavement and the existing building at 414 Rockaway Ave. to be resolved?
Answer: Protect the existing building in place. Do not impose additional loads on the walls of the existing building. The Contractor shall provide the minimum separation they can achieve between the existing building and the proposed pavement above existing grade.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Dolly Daniels".

Dolly Daniels, Senior Buyer
City of Grand Junction, Colorado