



Purchasing Division

ADDENDUM NO. 1

DATE: September 8, 2023
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: Canyon View Park Tennis Court Parking Stabilization IFB-5298-23-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. **Question:** SP-3 Wet-roller Compact Materials, is any information available on what stabilization treatment will be use by the third party? Will it be topically applied, and no effort needed to work treatment into the RAP other than Wet-Rolling?
Answer: The stabilization treatment will be topically applied by a water truck type applicator and required no additional effort to mix.

2. **Question:** SP-2 Section 203 – 3” millings, The gradation provided will be tough to source locally as this would need to be a blended material, not just crushed or screened.
 As an alternative gradation would this be considered?

	1	2	3	4	5		Average	St Dev
3/4"	100	100	100	100	100		100	0.0
1/2"	98.0	97.2	96.1	97.1	97.1		97	0.7
3/8"	90.3	90.7	89.7	88.0	86.3		89	1.8
#4	72.9	73.3	70.5	63.7	66.7		69	4.1
#8	55.3	55.4	50.4	46.3	47.5		51	4.3
#16	41.5	42.8	37.3	35.8	35.1		39	3.5
#30	32.6	33.5	28.9	29.1	27.3		30	2.6
#50	24.0	25.2	22.0	21.7	20.7		23	1.8
#100	16.5	17.4	15.4	14.3	14.6		16	1.3
#200	11.19	12.31	10.56	9.88	10.19		10.8	0.96

Answer: The alternative gradation proposed is an acceptable gradation.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Dolly Daniels". The signature is written in a cursive, flowing style.

Dolly Daniels, Senior Buyer
City of Grand Junction, Colorado