



Purchasing Division

## ADDENDUM NO. 2

**DATE:** September 12, 2023  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** Canyon View Park Tennis Court Parking Stabilization IFB-5298-23-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

- 1. Question:** Will a survey be provided for control set up?  
**Answer:** No survey will be provided and is not a project requirement.
- 2. Question:** Will compaction testing be required and if so, who provides?  
**Answer:** A proof roll of the subgrade material, witnessed by a City Project Engineer or Inspector is compaction requirement.
- 3. Question:** Per 3.3.13 City furnished Materials (None) Stabilization treatment is a city furnished or contractor furnished. Please clarify.  
**Answer:** The City is contracting with a third party to apply proprietary product after crushed millings placement and before the wet roll.
- 4. Question:** Will a grading permit be required for this project?  
**Answer:** No grading permit is required for this project.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Dolly Daniels".

Dolly Daniels, Senior Buyer  
City of Grand Junction, Colorado