



Purchasing Division

## **ADDENDUM NO. 2**

**DATE:** September 13, 2023  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** 2023 Sewer Replacement – Various Locations IFB-5289-23-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

- 1. Question:** Will Railroad Flagging, Track Protection or any other permits/coordination be required through BNSF to work at the South Avenue Rail Yard manhole?  
**Answer:** No flagging, track protection, or permits will be required at the South Avenue Railyard.
- 2. Question:** Please verify the invert depth of the manhole behind Tequila's restaurant.  
**Answer:** 51" (4'3") invert to Rim at Manhole behind Tequila's.
- 3. Question:** When will the Grand Valley Canal irrigation water be shutoff?  
**Answer:** Estimated to close late October to early November.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Dolly Daniels". The signature is written in a cursive, flowing style.

Dolly Daniels, Senior Buyer  
City of Grand Junction, Colorado