

## **ADDENDUM NO. 2**

**DATE:** October 10, 2023  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** Fabric Structure IFB-5299-23-KF

Offerors responding to the above-referenced solicitation are hereby instructed requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Regarding the question in addendum 1, about the one (1) opening (4'x4') to accommodate the conveyor belt, originally slated for an end wall penetration. After additional research, the project team has determined that the 4'x4' reinforced opening per Section 3.4.4., shall now be a side wall penetration.
2. **Q:** What type of vents does the City require for addressing condensation and dripping in the fabric structure: passive or mechanical?  
**A:** Passive, two (2) vents located at each end wall for a total of four (4) vents.
3. **Q:** What is the minimum leg requirement?  
**A:** six (6) foot.
4. **Q:** A 24' high arch-shaped fabric structure does not accommodate the clearance requirements for the larger 28' H x 20' W roll-up door. In order to meet the operational requirements of the larger door, does the City want to require all bids to be for a Gable shape?  
**A:** The Contractor shall provide a bid for a structure to meet all requirements. An arch-shaped or gable structure is acceptable.
5. **Q:** Are the provided/installed block walls required on the end walls, or will the fabric structure extend to the ground? If the fabric structure extends to the ground, what is the height of the block wall from zero?  
**A:** The Owner will provide the block walls along with a reinforced concrete foundation. Each end wall (fabric) will terminate at the ground and attach to the concrete foundation. The height of the walls is 6' (72 inches) from the finish

grade of the foundation. In addition, all framing shall consist of metal studs, no lumber shall be permitted.

The original solicitation for the project noted above is amended as noted.

All other conditions of the subject remain the same.

Respectfully,



Kathleen Franklin, Senior Buyer  
City of Grand Junction, Colorado