

## **ADDENDUM NO. 2**

**Date:** October 20, 2023  
**From:** City of Grand Junction Purchasing Division  
**To:** All Offerors  
**RE:** 24-inch MJ Gate Valve Qty 2 IFB-5318-23-KF

Offerors responding to the above-referenced solicitation are hereby instructed requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. **Q:** Would the City consider an alternate bid of “24” MJ X MJ Plug valves” for this proposal? Reason: In some applications such as this on raw water a plug valve may be a better choice.  
**A:** 24” MJ x MJ Gate Valve Only.
2. **Q:** Would the City consider an alternate bid of “24” MJ X MJ Butterfly valves” for this proposal? The option of either a plug valve or butterfly valve may be a better choice over a gate and a cost savings as well as a shorter lead time.  
**A:** 24” MJ x MJ Gate Valve Only.
3. **Q:** Will the City accept a different brand of restraint (Mega Lug) in place of the Ebba brand?  
**A:** Yes, will accept Ebba iron or equivalent MJ restraints.

The original solicitation for the project noted above is amended as noted.

All other conditions of the subject remain the same.

Respectfully,



Kathleen Franklin, Senior Buyer  
City of Grand Junction, Colorado