



## **ADDENDUM NO. 3**

**Date:** October 26, 2023  
**From:** City of Grand Junction Purchasing Division  
**To:** All Offerors  
**RE:** 24-inch MJ Gate Valve Qty 2 IFB-5318-23-KF

Offerors responding to the above-referenced solicitation are hereby instructed requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. **Q:** Will the installation of the valves be vertical or horizontal? This does change the gear configuration.

**A:** Vertical.

The original solicitation for the project noted above is amended as noted.

All other conditions of the subject remain the same.

Respectfully,

A handwritten signature in blue ink, appearing to read "K. Franklin".

Kathleen Franklin, Senior Buyer  
City of Grand Junction, Colorado