



Purchasing Division

ADDENDUM NO. 1

DATE: November 9, 2023
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: 2023 Sewer Replacements Pases 6, 8, & 10 Open Cut

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

- 1. **Question:** My landscaper is asking if we can get a seed spec for the .1 acres on the sewer replacement project.

Answer:

City of Grand Junction, Colorado
 Standard Specifications for Road and Bridge Construction

SECTION 212 - SEEDING, FERTILIZER AND SODDING

MATERIALS

212.02 Seed, Fertilizer and Sod

ADD THE FOLLOWING TO PARAGRAPH (a) *SEED*:

Dryland seed mix shall be as follows unless otherwise approved by the City's Forestry Supervisor:

Description	PLS rates per acre (100%)	% of mix	PLS rate per species per acre
Crested Wheatgrass, Ephraim	6	20%	1.25
Western Wheatgrass, Arriba	16	20%	3.25
Smooth Brome, Lincoln	12	15%	2.0
Alkali Sacaton	0.5	10%	0.25
Viva Galleta Grass	12	10%	1.25
Orchard grass, Paiute	4	10 %	0.5
Perennial Ryegrass, Tetraploid	8	15%	1.25
Oats or Winter Wheat	add in	add in	3.0
Total		100	12.75
Drilled rate @ 12.75 lbs/acre			
Broadcast rate @ 25.5 lbs/acre			

The original solicitation for the project noted above is amended as noted. All other conditions of the subject remain the same.

Respectfully,

Dolly Daniels, Senior Buyer
 City of Grand Junction, Colorado