



Purchasing Division

## ADDENDUM NO. 1

**DATE:** January 16, 2024  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** Roof Replacements City Hall and City Offices

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

- Question:** I would like to inquire about the existing roof, how many layers and the decking.  
**Answer:** Existing roof is a ballasted single-ply Firestone rubber membrane roofing system on tapered insulation and crickets system (R-25 average) with the minimum thickness of one-inch. There is currently one layer of roofing. Per sheet S1.3: The existing deck is 3.5 inches concrete on 9/16" steel form deck.

The original solicitation for the project noted above is amended as noted. All other conditions of the subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Dolly Daniels".

Dolly Daniels, Senior Buyer  
City of Grand Junction, Colorado