

Purchasing Division

ADDENDUM NO. 5

DATE: January 29, 2024

FROM: City of Grand Junction Purchasing Division

TO: All Offerors

RE: Road Reconstruction Yucatan Ct and Summerhill Ct IFB-5359-24-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

- 1. Question: According to spec section 3.3.20 "Contractor will perform QC testing on the concrete. The City will perform all other necessary QA/QC." Does that include the Class 6 compaction testing under the asphalt and concrete? Does the City pay or do I as the GC have to pay for QA testing?
 - Answer: The Contractor is responsible for Quality Control (QC) for process control purposes and shall include concrete testing (by supplier or contractor) necessary to insure control of the delivered materials. The City has hired RockSol Consulting to provide all Quality Assurance (QA) testing for acceptance purposes.

The original solicitation for the project noted above is amended as noted. All other conditions of the subject remain the same.

Respectfully,

Saley Barie to

Dolly Daniels, Senior Buyer City of Grand Junction, Colorado