

ADDENDUM NO. 1

Date: April 12, 2024
From: City of Grand Junction Purchasing Division
To: All Offerors
RE: Purchase and Installation of Ballistic-Rated Glass, IFB-5432-24-KF

Offerors responding to the above-referenced solicitation are hereby instructed requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. **Q:** Would the City consider using an alternate product versus installing new ballistic glass? Specifically, UL752 Bullet-resistant film achieves Level 2 on dual pane 1/4-inch glass.

A: Yes, the City would accept an alternate product, provided it meets or exceeds [UL752 Bullet-resistant film specifications](#) (link).

2. All Offerors are required to utilize the Addendum 1 Price Schedule form provided via the link below for its bid response. Additionally, the form is attached to this addendum for easy reference.

[Addendum 1 Price Schedule IFB-5432-24-KF](#)

The original solicitation for the project noted above is amended as noted.

All other conditions of the subject remain the same.

Respectfully,



Kathleen Franklin, Senior Buyer
City of Grand Junction, Colorado

Addendum 1 Price Bid Schedule IFB-5432-24-KF

"Purchase and Installation of Ballistic-Rated Glass"

The Contractor shall provide all necessary labor, materials, supplies, equipment, tools, incidentals, permits and insurance necessary for the purchase and installation of ballistic-rated glass following the IFB.

Lead time, warranty, and specification information must be included in the bid response, per Section 3.17.12.

Item No.	Floor	Location:	Quantity Units	Size	BR Level	UL752 Bullet-Resistant Film	Glass Unit Price	Extended Price
1	2nd	Dispatch - Training Room	6	21 3/4 x 37 1/4	Level 2	\$ _____	\$ _____	\$ _____
2	2nd	Dispatch - Main	8	25 1/2 x 35 1/2	Level 2	\$ _____	\$ _____	\$ _____
3	2nd	Dispatch - Break Room	4	21 3/4 x 37 1/4	Level 2	\$ _____	\$ _____	\$ _____
4	2nd	Dispatch Door - Break Room	1	25 1/2 x 36 1/2	Level 2	\$ _____	\$ _____	\$ _____
5	2nd	Dispatch - Supervisor	2	21 3/4 x 37 1/4	Level 2	\$ _____	\$ _____	\$ _____
6	2nd	Victims Advocate	4	24 x 44	Level 2	\$ _____	\$ _____	\$ _____
7	2nd	Training Room East & West	4	41 1/2 x 44 3/4	Level 2	\$ _____	\$ _____	\$ _____
8	2nd	Training Room North	14	24 x 44	Level 2	\$ _____	\$ _____	\$ _____
9	2nd	IT Room	6	21 3/4 x 37 1/4	Level 2	\$ _____	\$ _____	\$ _____
10	1st	Inside Property Entry Door Glass	3	7 x 32	Level 3	\$ _____	\$ _____	\$ _____
11	1st	Middle lobby sidelight	1	18 x44	Level 3	\$ _____	\$ _____	\$ _____
12	1st	Middle lobby sidelight	1	18 x 34	Level 3	\$ _____	\$ _____	\$ _____

Subtotal quantity units 54

Bid Amount: \$ 0

Total Bid Price Written: _____ dollars.

Bid Alternate 1							
Item No.	Floor	Location:	Quantity Units	Size	BR Level	Glass Unit Price	Extended Price
BA1.1	2nd	Dispatch Door Frame, BR Glass, and all required components (instead of item #4 above).	1	36 x 80	Level 3	\$ _____	\$ _____
BA1.2	2nd	or any necessary updates or upgrades to the existing Dispatch Door Frame, such as hinges, to ensure its capability to support the weight of the ballistic-resistant glass (in conjunction with item #4 above).	tbd	n/a	Level 3	\$ _____	\$ _____

Bid Alternate No. 1 Bid Amount: \$ _____

Bid Alternate 1 Total Bid Price Written: _____ dollars.

"Purchase and Installation of Ballistic-Rated Glass"

Add Alternate 1

Item No.	Floor	Location:	Quantity Units	Size	BR Level	UL752 Bullet-Resistant Film	Glass Unit Price	Extended Price
AA1.1	2nd	Digital Lab lower pane only	1	21 3/4 x 37 3/4	Level 2	\$ _____	\$ _____	\$ _____
AA1.2	2nd	Digital Lab lower pane only	4	21 3/4 x 29 3/4	Level 2	\$ _____	\$ _____	\$ _____
AA1.3	2nd	Investigations lower pane only	6	37 3/4 x 25 3/4	Level 2	\$ _____	\$ _____	\$ _____
AA1.4	2nd	Investigations lower pane only	6	37 3/4 x 25 1/2	Level 2	\$ _____	\$ _____	\$ _____
AA1.5	2nd	Investigations lower level only	10	21 3/4 x 37 3/4	Level 2	\$ _____	\$ _____	\$ _____
AA1.6	2nd	PIO	4	21 3/4 x 37 3/4	Level 2	\$ _____	\$ _____	\$ _____
AA1.7	2nd	Chief's Office Windows	2	37 3/4 x 37 5/8	Level 2	\$ _____	\$ _____	\$ _____
AA1.8	2nd	Admin/Admin	2	37 3/4 x 37 5/8	Level 2	\$ _____	\$ _____	\$ _____
AA1.9	2nd	East - Accounting	2	37 3/4 x 33 1/2	Level 2	\$ _____	\$ _____	\$ _____
AA1.10	2nd	Admin Offices	12	25 1/2 x 44 3/4	Level 2	\$ _____	\$ _____	\$ _____
AA1.11	2nd	Admin Offices	2	21 3/4 x 37 1/4	Level 2	\$ _____	\$ _____	\$ _____

Subtotal quantity units 51

Add Alternate No. 1 Bid Amount: \$ _____ **0**

Add Alternate 1 Total Bid Price Written: _____ dollars.

"Purchase and Installation of Ballistic-Rated Glass"

Add Alternate 2							
Item No.	Floor	Location:	Quantity Units	Size	BR Level	Glass Unit Price	Extended Price
AA2.1	1st	Back Lower Level	2	25 3/4 x 65 1/2	Level 3	\$ _____	\$ _____
AA2.2	1st	Back Double Door	2	25 1/2 x 36 1/2	Level 3	\$ _____	\$ _____
AA2.3	1st	South Facing	10	21 3/4 x 37 1/2	Level 3	\$ _____	\$ _____
AA2.4	1st	Back Gym Door	1	35 x 67 1/2	Level 3	\$ _____	\$ _____

Subtotal quantity units **15**

Add Alternate No. 2 Bid Amount: \$ _____ **0**

Add Alternate 2 Total Bid Price Written: _____ dollars.

Bid Alternate 2 for Add Alternate 2							
Item No.	Floor	Location:	Quantity Units	Size	BR Level	Glass Unit Price	Extended Price
BA2.1	1st	Back Double Door Frame, BR Glass, and all required components (instead of item #AA2.2 above).	2	36 x 80	Level 3	\$ _____	\$ _____
BA2.2	1st	or any necessary updates or upgrades to the existing Back Double Door Frame, such as hinges, to ensure its capability to support the weight of the ballistic-resistant glass (in conjunction with item #AA2.2 above).	tbd		Level 3	\$ _____	\$ _____
BA2.3	1st	Back Gym Door Frame, BR Glass, and all required components (instead of item #AA2.4 above).	1	36 x 80	Level 3	\$ _____	\$ _____
BA2.4	1st	or any necessary updates or upgrades to the existing Back Gym Door Frame, such as hinges, to ensure its capability to support the weight of the ballistic-resistant glass (in conjunction with item #AA2.4 above).	tbd		Level 3	\$ _____	\$ _____

Bid Alternate No. 2 Bid Amount: \$ _____ **0**

Bid Alternate 2 Total Bid Price Written: _____ dollars.

"Purchase and Installation of Ballistic-Rated Glass"

Add Alternate 3							
Item No.	Floor	Location:	Quantity Units	Size	BR Level	Unit Price	Extended Price
AA3.1	1st	Front Entry Lobby	3	37 1/4 x 47 3/4	Level 3	\$ _____	\$ _____
AA3.2	1st	Floor Front Entry Lobby	3	37 1/4 x 33 3/4	Level 3	\$ _____	\$ _____

Subtotal quantity units 6

Add Alternate No. 3 Bid Amount: \$ _____ **0**

Add Alternate 3 Total Bid Price Written: _____ dollars.

Ballistic-Rated Glass Lead Time: _____

Estimated Schedule and Project Timeline: _____

Is the Ballistic-Rated Level 2 and Level 3 Specifications and Warranty Information attached to the Bid Response? _____

How much is the estimated cost increase over the next four years, based on the Producer Price Index (PPI)?

	Level 2	Level 3
2025-2026	_____	_____
2026-2027	_____	_____
2027-2028	_____	_____
2028-2029	_____	_____