



Purchasing Division

### ADDENDUM NO. 3

**DATE:** July 8, 2024  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** Kannah Creek Water Storage Tank Project IFB-5468-24-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. **Question:** Can the appurtenances such as ladders, hatches, handrails, etc. be coated to match the tank if it is a welded steel tank?  
**Answer:** This is covered by par 2.4 of Section 13340. Interior ladder (fiberglass or aluminum), Exterior ladder can be coated with the exterior coating system, The specifications do not call out material for the hatch or handrail, so steel coated to match the tank is permissible.
2. **Question:** If a welded steel tank is submitted, does the Owner still want the drain sump?  
**Answer:** Yes
3. **Question:** The welded steel tank specification mentions a 36" square roof hatch is desired whereas the drawing S1.1 shows a 36" X 48" aluminum hatch. If a welded steel tank is submitted, can the hatch be a 36" square steel hatch coated to match the tank?  
**Answer:** All hatches should be 36" x 48". The hatch may be coated to match the welded steel tank.

The original solicitation for the project noted above is amended as noted. All other conditions of the subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Dolly Daniels".

Dolly Daniels, Senior Buyer  
City of Grand Junction, Colorado