



Purchasing Division

ADDENDUM NO. 4

DATE: August 13, 2024
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: 2024 City of Grand Junction Building Lighting Upgrades IFB-5483-24-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

- 1. Question:** For energy savings what kWh do you want us to use as a standard for your interior applications? Xcel might have given you one at the time of the audit.
Answer: Please use the annual hours of operation to calculate kWh.
- 2. Question:** For energy savings what kWh do you want us to use as a standard for your exterior applications? Xcel might have given you one at the time of the audit.
Answer: Please use the annual hours of operation to calculate kWh.
- 3. Question:** There are some lamp count & fixture types that are listed that state a specific wattage is being used on a fixture, however that wattage is non-existent in that length bulb. Can I use the standard wattage for a 2 lamp 75w T12 fixture since there is no 40w 8' bulb ever made.
Answer: Yes, you can use standard wattage for a 2 lamp 75w T12 fixture.

The original solicitation for the project noted above is amended as noted. All other conditions of the subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Dolly Daniels".

Dolly Daniels, Senior Buyer
City of Grand Junction, Colorado