

Purchasing Division

ADDENDUM NO. 1

DATE: August 16, 2024

FROM: City of Grand Junction Purchasing Division

TO: All Offerors

RE: Design Services for Juniata Dam Outlet Replacement RFP-5484-24-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Question: The description of the desired changes on page 15 states," The City desires to change the configuration of the outlet piping on the upstream side of the dam by removing the two 12" hydraulically operated gate valves and the dual 12" pipes, and replacing this dual pipe configuration with one steel pipe and install a new manually operated outlet valve...The City desires to utilize the existing trash rack and new hydraulic lines operating the gate valves, on the low level, if possible." Please confirm that hydraulically actuated valves operated on site are desired and not manually operated valves.

Answer: This is a hydraulic system that is operated manually, meaning the operator needs to go in the valve building at the top of the dam and operate the hydraulic valves to either open or close them. This hydraulic system was recently replaced, and the City would rather not redo the valve operating system for this new valve.

 Question: Please confirm the scope of the stormwater management plan is limited to what is necessary to support the construction of the modifications to the outlets.
Answer: That is correct.

The original solicitation for the project noted above is amended as noted. All other conditions of the subject remain the same.

Respectfully,

Daley Barie to

Dolly Daniels, Senior Buyer City of Grand Junction, Colorado