



Purchasing Division

## ADDENDUM NO. 1

**DATE:** August 19, 2024  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** DeZURIK Valves and Hardware IFB-5493-24-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. **Question:** What type of material for the gaskets?  
**Answer:** Rubber
2. **Question:** What type of material for the bolts/nuts?  
**Answer:** Zinc Coated Steel
3. **Question:** No washers are required, correct?  
**Answer:** Correct, No washers are required.
4. **Question:** Would the City accept Crispin valve be accepted as an equal to the Dezurik specified? Crispin valve meets the specifications requirements. Crispin Valve is approved at many cities across the US along with Dezurik and a few other manufacturers.  
**Answer:** We are requiring DeZuriks for this application, because raw sewage is an essential pinch point in our operations, we require that all the valves be from the same manufacturer - the other valves are DeZuriks, and this enables us to maintain redundancy and maximize flexibility for repairs during emergencies.
5. **Clarification:** The "Hardware Kits" have been removed from the Price Bid Schedule. Please use the attached revised Price Bid Schedule when submitting your bid.

The original solicitation for the project noted above is amended as noted. All other conditions of the subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Dolly Daniels".

Dolly Daniels, Senior Buyer  
City of Grand Junction, Colorado

**IFB-5493-24-DD “DeZURIK Valves and Hardware”  
PRICE BID SCHEDULE: Addendum No. 1**

Item	Description	Quantity	Units	Unit Price	Extended Price
1	DeZURIK Valves	11	EA.	\$ _____	\$ _____
2	1-1/8” X 4” Bolts w/ Nuts	290	EA.	\$ _____	\$ _____
3	1-1/8” X 4” Studs w/ Nuts	120	EA.	\$ _____	\$ _____
4	18” Flange Gaskets	25	EA.	\$ _____	\$ _____
<b>Total Extended/Bid Price</b>					\$ _____

**Total Extended Bid Amount Written**

\_\_\_\_\_ Dollars

**Warranty (State warranty and provide manufacturer’s statement)**

\_\_\_\_\_

**Provide the Manufacturer Specification Information**

\_\_\_\_\_

**Provide Estimated Project Lead Time**

\_\_\_\_\_

*By signing below, the Undersigned agree to comply with all terms and conditions contained herein.*

**Company:** \_\_\_\_\_

**Authorized Signature:** \_\_\_\_\_

**Title:** \_\_\_\_\_

**Date:** \_\_\_\_\_