



Purchasing Division

ADDENDUM NO. 2

DATE: August 26, 2024
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: Sewer Replacement 12th Street and Wellington Avenue IFB-5487-24-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

- Question:** Bid item 22 "Concrete Flatwork" appears to be 3 different sections or 8" concrete: Trash enclosure, misc. concrete apron, and a driveway apron. Besides doweling into existing per the City's detail C-32, does the City want any reinforcement in any of the concrete for this bid item 22?
Answer: #3 rebar spaced 18" on center each way

The original solicitation for the project noted above is amended as noted. All other conditions of the subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Dolly Daniels".

Dolly Daniels, Senior Buyer
City of Grand Junction, Colorado