

**Purchasing Division** 

## ADDENDUM NO. 1

DATE: November 15, 2024

FROM: City of Grand Junction Purchasing Division

TO: All Offerors

RE: HVAC Purchase and Installation at 333 West Ave Building B IFB-5535-24-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

1. Clarification: All condensate drains will be run outside and have a condensate neutralizer installed.

The original solicitation for the project noted above is amended as noted. All other conditions of the subject remain the same.

Respectfully,

Saley Barrets

Dolly Daniels, Senior Buyer City of Grand Junction, Colorado