



Purchasing Division

## **ADDENDUM NO. 1**

**DATE:** November 20, 2024  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** Recycling Facility – Fabric Building Re-Cover IFB-5539-24-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. **Question:** Are there pictures of the existing building showing the termination of the fabric?  
**Answer:** See attached pictures.
2. **Question:** Confirming that the building is 32'W X 30'L?  
**Answer:** Correct.
3. **Question:** What color for the fabric?  
**Answer:** Tan or white
4. **Question:** Are there drawings for the existing building?  
**Answer:** No
5. **Question:** Do you know the truss spacing?  
**Answer:** Every Ten Feet
6. **Question:** Do you know the location of the vertical steel in the end wall?  
**Answer:** Refer to the attached pictures
7. **Question:** Are there any mesh vents required in the new end wall?  
**Answer:** No
8. **Question:** Final completion date of 12/31 may be hard to achieve, lead time on the fabric is 2-3 weeks after the order is placed so will additional time be allowed to complete the project?  
**Answer:** The City will work with the Contractor in the completion date based on material lead times.

The original solicitation for the project noted above is amended as noted. All other conditions of the subject remain the same.

Respectfully,

*Dolly Daniels*

Dolly Daniels, Senior Buyer  
City of Grand Junction, Colorado









OFFICE PAPER  
PLASTICS &  
NEWSPRINT MAG  
STEEL CANS ALUM  
GLASS JARS & BOT  
CORRUGATED CARD

















