

Purchasing Division

ADDENDUM NO. 1

DATE: December 20, 2024

FROM: City of Grand Junction Purchasing Division

TO: All Offerors

RE: Four Canyons Parkway Phase 2A Relocation and Construction of Underground

Utilities IFB-5552-24-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following questions/answers/clarifications:

 Question: Would Prinsco GoldFlo Dual Wall Corrugated HDPE be an acceptable alternative to the reinforced concrete pipe called out on lines 13 and 14 of the bid schedule?
 Answer: Dual wall or corrugated polypropylene pipe will be considered an approved equivalent for Reinforced Concrete Pipe, when installed in accordance with CDOT M Standards.

2. Question: Please see attached spec sheet for ADS HP STORM pipe to possibly be used as an RCP alternate, used in previous phase.

Answer: Please see answer to question #1 above.

The original solicitation for the project noted above is amended as noted. All other conditions of the subject remain the same.

Respectfully,

Sury Sariets

Dolly Daniels, Senior Buyer

City of Grand Junction, Colorado