



Purchasing Division

ADDENDUM NO. 2

DATE: January 9, 2025
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: Crosby Avenue Utility Relocation IFB-5554-24-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following questions/answers/clarifications:

- 1. Question:** Can the sanitary sewer pipe be installed in an open trench?
Answer: This will not be permitted due to existing improvements and impacts to business operations.
- 2. Question:** Can the sewer video be made available?
Answer: The sewer videos and observation reports are being made available with this addendum.
- 3. Question:** Can Nyloplast basins be used instead of manholes?
Answer: The City standard is to use a concrete manhole for this application.

Here's a link to the sewer video and inspection reports. The video files are quite large. The project geotech report is also included in this link. This will assist with the bidders ability to see where they can expect to encounter unstable soils and groundwater: [20250108-Crosby Utilities](#)

The original solicitation for the project noted above is amended as noted. All other conditions of the subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Dolly Daniels".

Dolly Daniels, Senior Buyer
City of Grand Junction, Colorado