



Purchasing Division

**ADDENDUM NO. 2**

**DATE:** January 13, 2025  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** Waterline Replacement – Linden Avenue Phase 1

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following questions/answers/clarifications:

- 1. **Question:** All caps- what type of pipe is existing? Need to know for proper cap type.  
**Answer:** End Cap quantity with pipe diameter & material type.

Quantity	Ø	material
3	8"	Cast Iron
7	24"	Steel Pipe O.D. 25.80"
2	8"	Asbestos Concrete
5	8"	PVC

**SUBMIT THE ATTACHED REVISED BID SCHEDULE WITH BID (Item #5 has been corrected per the above)**

The original solicitation for the project noted above is amended as noted. All other conditions of the subject remain the same.

Respectfully,

Dolly Daniels, Senior Buyer  
City of Grand Junction, Colorado

**PRICE BID SCHEDULE ADDENDUM No. 2**  
**Waterline Replacement Linden Ave Phase 1**  
**IFB-5556-25-DD**

Item No.	(Div No.)	Description	Quantity	Units	Unit Price	Total Price
1	103.16	Export Trench Spoils	670	CY	\$ _____	\$ _____
2	108.2	Water Main (4") (C-900 PVC, DR-18)	5	LF	\$ _____	\$ _____
3	108.2	Water Main (6") (C-900 PVC, DR-18)	70	LF	\$ _____	\$ _____
4	108.2	Water Main (8") (C-900 PVC, DR-18)	40	LF	\$ _____	\$ _____
5	108.2	Water Main (20") (C-905 PVC, DR-25)	1960	LF	\$ _____	\$ _____
6	108.3	Elbow - 11.25° (20")	3	EA	\$ _____	\$ _____
7	108.3	Elbow - 22.5° (20")	4	EA	\$ _____	\$ _____
8	108.3	Elbow - 45° (20")	3	EA	\$ _____	\$ _____
9	188.3	End Cap Ø8"	10	EA	\$ _____	\$ _____
10	188.3	End Cap Ø24"	7	EA	\$ _____	\$ _____
11	108.3	Tee (20" x 4")	1	EA	\$ _____	\$ _____
12	108.3	Tee (20" x 6")	1	EA	\$ _____	\$ _____
13	108.3	Tee (20" x 8")	2	EA	\$ _____	\$ _____
14	108.3	Fire Hydrant Assembly (6")	2	EA	\$ _____	\$ _____
15	108.4	Water Service Line (3/4") (Type K Copper)	225	LF	\$ _____	\$ _____
16	108.4	Gate Valve (4")	1	EA	\$ _____	\$ _____
17	108.4	Gate Valve (6")	1	EA	\$ _____	\$ _____
18	108.4	Gate Valve (8")	2	EA	\$ _____	\$ _____
19	108.4	Butterfly Valve (20")	4	EA	\$ _____	\$ _____
20	102.8/108.3	Fittings	1	EA	\$ _____	\$ _____
21	201	Clear & Grub	1	LS	\$ _____	\$ _____
22	202	Removal of Concrete	340	SF	\$ _____	\$ _____
23	202	Removal of Asphalt	16,285	SF	\$ _____	\$ _____
24	202	Demolish Existing 20-Inch Water Line	10	LF	\$ _____	\$ _____
25	202	Remove Existing Fire Hydrant (Return Hydrant to City Shops)	1	EA	\$ _____	\$ _____
26	202	Sand Aggregate Flow Fill Existing 24" Steel Water Main	255	CY	\$ _____	\$ _____
27	208	Erosion & Sediment Control	1	LS	\$ _____	\$ _____
28	212	Seeding (20 lbs/AC)	1	LS	\$ _____	\$ _____
29	304	Aggregate Base Course (Class 6) (6" thick)	550	TON	\$ _____	\$ _____
30	401	Hot Bituminous Pavement (patching) (4" thick) (grading SX, binder grade PG 64-22) (two 2" lifts)	395	TON	\$ _____	\$ _____
31	608.06	Concrete Drainage Pan (6' wide)	57	LF	\$ _____	\$ _____
32	608.06	Concrete Driveway Section (8" thick) (Commercial)	106	SF	\$ _____	\$ _____
33	625	Construction Surveying	1	LS	\$ _____	\$ _____
34	626	Mobilization	1	LS	\$ _____	\$ _____
35	630	Traffic Control	1	LS	\$ _____	\$ _____
36	630	Traffic control message boards (each, per day)	1	Day	\$ _____	\$ _____
37	F/A	Utility Allowance Support/Relocate Existing Utilities	1	EA	\$ _____	\$ _____
38	F/A	Flow Fill Allowance	1	Yd	\$ _____	\$ _____
39	F/A	Unawweep Ave Early Finish Incentive	1	LS	\$ 8,500.00	\$ 8,500.00
40		Minor Contract Revisions (MCR)				\$250,000.00

**Total Bid** \$ \_\_\_\_\_

**Total Amount of Bid (Written)** \_\_\_\_\_ **Dollars**