



Purchasing Division

ADDENDUM NO. 1

DATE: March 3, 2025
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: Environmental Controls at Botanical Gardens RFQ-5612-25-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following questions/answers/clarifications:

1. **Question:** There is a request for providing a dial out option for alarming; is there a network available in the building for the new BAS to send out alarms via email/text?
Answer: Yes, there is a network available.
2. **Question:** Pricing structure; there is a note in the RFQ for breaking out pricing based on anything with quantities (ie, to my understanding, that would mean if there was pricing provided for controls of (2) boilers, you are requesting pricing to be separated for each boiler) is that correct and are there any other pricing break-outs that are required?
Answer: There is not any pricing break out required for this RFQ. Bid everything together as lump sum.

The original solicitation for the project noted above is amended as noted. All other conditions of the subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Dolly Daniels".

Dolly Daniels, Senior Buyer
City of Grand Junction, Colorado