



Purchasing Division

ADDENDUM NO. 1

DATE: May 13, 2025
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: 7th to 15th Ouray Replacement - Pipe & Supplies Materials Purchase Only IFB-5677-25-KN

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. **Q:** How is the City measuring the 4-1/2' Fire Hydrants for this project?

A: It's a 4 ½ foot bury depth.

2. **Q:** We are noticing on the bid tab that some of the MJ Fittings lines include accessory parts and some do not. Does the City want all MJ Fittings and Flanged Fittings to include accessories, or just the ones specified on the bid tab?

A: All line items should include accessories.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink that reads "K Nelson".

Kassy Nelson, Buyer
City of Grand Junction, Colorado