



Purchasing Division

## **ADDENDUM NO. 1**

**DATE:** May 20, 2025  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** 2025 Curb, Gutter, Sidewalk Project IFB-5670-25-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following questions/answers/clarifications:

**1. Question:** The bid schedule calls for 200 SY of asphalt, however the sheet that lists the locations only has 50. Which one is correct?

**Answer:** Up to 200 SY of asphalt patching is allowed for to match street conditions and allow for forming if necessary. The 50 SY was a specially identified section that will require patching to meet grades.

The original solicitation for the project noted above is amended as noted. All other conditions of the subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Dolly Daniels".

Dolly Daniels, Senior Buyer  
City of Grand Junction, Colorado