



Purchasing Division

## **ADDENDUM NO. 1**

**DATE:** June 9, 2025  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** Field Netting for Columbine Park RFQ-5693-25-KN

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. **Q:** Is there a need for 40ft overall height for the post? Would 35 suffice since that would be the over height of the netting?  
**A:** 35' posts are adequate.
2. **Q:** Would galvanized metal pipe be sufficient for the post?  
**A:** Galvanized is acceptable, please include the price of black as an alternate. The company shall submit pricing on addendum one version of the price quote schedule below.
3. **Q:** Which side of the fence would the netting be installed?  
**A:** West would be preferable, but we are open to recommendations.
4. **Q:** Would the netting be allowed to tie in with the existing back stop? This would allow for one less post in the foul territory.  
**A:** Tied into the backstop is acceptable.
5. **Q:** Could the area in the dugout be completed with chain link to fill in the gap below the netting?  
**A:** If the location is between the existing fence and the inside roofline, there is no expectation of fence or net. We may need to look at this for verification.
6. **Q:** Is the timeline flexible to wait for harder ground conditions to minimize damage to existing turf?  
**A:** Timeline is flexible. However, due to grant funding, the project may have to be performed by the end of the year. We can discuss further with awarded Contractor.
7. **Q:** The requested product was range netting for golf usage, we would like to install netting specifically for baseball/ softball.

**A:** Preference is toward netting for baseballs and softballs, no longer the golf netting specified in solicitation.

8. **Q:** Will we be required to install padding on the new metal post for the netting? If so, is there a preference of style, thickness or color?

**A:** No, the City will provide padding.

9. **Q:** We will propose the netting to tie into the existing dugout at the same height (approx 20 ft). Once the netting is installed above the dugout it will terminate to the first 35 ft high post where it will continue to the end with a height of 35 ft. My question is, can the netting that is tied into the back stop and over the dugout be the same height as the backstop? The rest of the netting that stretches from the end of the dugout to the warning track will be overall 35 ft in height.

**A:** Yes, the netting can be equivalent to the height of the backstop to the north end of the dugouts. At this point it should increase to 35' to the warning track.

10. **Q:** Who will be responsible for locating private utilities on site?

**A:** The City will provide private locates, we will need 2 weeks' notice ahead of construction.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink that reads "K Nelson". The signature is written in a cursive, flowing style.

Kassy Nelson, Buyer  
City of Grand Junction, Colorado

**ADDENDUM 1 PRICE QUOTE SCHEDULE: RFQ-5693-25-KN Field Netting for Columbine Park**

<b>Description</b>	<b>Lump Sum</b>
Provide all labor, equipment, and materials for the installing a safety net and galvanized poles to divide the two softball fields at Columbine Park as described in Section 3.2	\$ _____
<b><u>BID ALTERNATE:</u></b> Provide all labor, equipment, and materials for the installing a safety net and <b>black</b> poles to divide the two softball fields at Columbine Park as described in Section 3.2	\$ _____

Total Lump Sum Amount Written:

\_\_\_\_\_ Dollars

Bid Alternate Total Lump Sum Amount Written:

\_\_\_\_\_ Dollars

**Brand Name of Netting Provided: (attach material specification sheet)**

\_\_\_\_\_

*By signing below, the Undersigned agree to comply with all terms and conditions contained herein.*

**Company:** \_\_\_\_\_

**Authorized Signature:** \_\_\_\_\_

**Title:** \_\_\_\_\_

**Date:** \_\_\_\_\_