



Purchasing Division

ADDENDUM NO. 1

DATE: August 21, 2025
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: 2025 Contract Street Maintenance Neighborhood Mill and Overlay IFB-5723-25-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following questions/answers/clarifications:

1. Question: Would the Cretex Pro Ring be approved as an equal to the concrete grade rings for this project?

Answer: Manhole Grade Rings: Concrete grade rings, shims and non-shrink grout shall not be used on the sewer manhole riser sections. Approved grade rings for this project shall be either HDPE Adjusting Rings by LadTech, Inc. or Expanded Polypropylene grade rings by Cretex Pro-Ring.

Grade rings shall be installed per the manufacturer's recommendations and directions. Caulk and sealants shall be approved by the manufacturer and shall be applied per the manufacturer's recommendation. Adjust the top grade ring to match the existing roadway cross-slope as closely as possible. Both manufacturers of grade rings provide adjustable grade rings that can accommodate the existing roadway cross-slope.

The original solicitation for the project noted above is amended as noted. All other conditions of the subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Dolly Daniels".

Dolly Daniels, Senior Buyer
City of Grand Junction, Colorado