



Purchasing Division

ADDENDUM NO. 2

DATE: November 21, 2025
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: D ½ Road Capacity Improvements IFB-5755-26-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following questions/answers/clarifications:

1. Clarification:

- Ute Water and Xcel Energy both intend to construct their own respective utility infrastructure during this project.
- Concrete mix designs for the project shall meet current CDOT Standard Specifications Section 901 for concrete mixtures for Class 3 Sulfate Exposure. This was tested for and recommended in the Geotechnical Report, which is included as Appendix E in the Solicitation.

The original solicitation for the project noted above is amended as noted. All other conditions of the subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Dolly Daniels".

Dolly Daniels, Senior Buyer
City of Grand Junction, Colorado