



Purchasing Division

## **ADDENDUM NO. 5**

**DATE:** December 2, 2025  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** D ½ Road Capacity Improvements IFB-5755-26-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following questions/answers/clarifications:

**1. CLARIFICATION:** To clarify the discrepancy between addendum 2 and addendum 4 with respect to maximum allowable Water / Cementitious Ratio, this project will have a maximum WCR of 0.40. All other requirements of addendum 4 should be observed.

The original solicitation for the project noted above is amended as noted. All other conditions of the subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Dolly Daniels".

Dolly Daniels, Senior Buyer  
City of Grand Junction, Colorado