



ADDENDUM NO. 2

Date: December 23, 2025

From: City of Grand Junction Purchasing Division

To: All Proposers

RE: *Supervisory Control and Data Acquisition (SCADA) and Instrumentation & Control (I&C) Support Services for the City of Grand Junction Persigo Wastewater Treatment Plant, RFP-5764-25-KF*

Proposers responding to the above-referenced solicitation are hereby advised that certain requirements have been **clarified, modified, or supplemented** as of the date of this Addendum, as outlined below.

Please take note of the following:

1. **Question:** What is the manufacturer and version of the current SCADA software?

Answer: See the City's response to Question 4 in Addendum No. 1. The City utilizes the Ignition SCADA platform, operating on version 8.1.

2. **Question:** What is the manufacturer and version of the current HMI Hardware and Software?

Answer: The City's current HMI hardware utilizes Siemens WinCC, version 18.3.

3. **Question:** Can you provide us with the network architecture of the SCADA system?

Answer: This question has been addressed. Please see Addenda 1 and 2. The City has clarified that:

- ICS network switches and related infrastructure are administered by the City's Information Technology (IT) Department.
- Lift stations are not directly integrated into the Persigo WWTP plant SCADA system.
- Lift station telemetry and monitoring are provided through a third-party system (AE2S), which includes a web-based portal, alarm callout functionality, and data historian services.

These clarifications are provided in Addendum No. 2, addressing cybersecurity responsibilities and the separation between plant SCADA systems and lift station

telemetry. Detailed network architecture diagrams are not provided as part of this solicitation.

4. **Question:** Will the supply of parts, spare parts, and equipment be the responsibility of the city or the contractor, plus a percentage of profit on the purchase price?

Answer: See the City's response to Question 7 in Addendum No. 2.

No further questions will be accepted at this time.

This addendum amends the original solicitation for the referenced project as outlined above. All other terms and conditions of the solicitation remain unchanged.

Proposers must acknowledge receipt of this addendum by completing the acknowledgment section on the **Solicitation Response Form** (Section 7.0).

Thank you for your attention to this matter.

Respectfully,

A handwritten signature in blue ink, appearing to read 'K. Franklin', is positioned above the typed name.

Kathleen Franklin
Senior Buyer/Purchasing Agent
City of Grand Junction